



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4355

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3321/17 Pt.1 T/J(228)

24 March 2017

### Approval of "PSV" Check Valves

Your letters ref. WSD-1422-17-L001 and WSD-1422-17-L002 dated 8 March 2017 and 10 March 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1422 (50mm)	164361ST161054(8)	4 Mar 2017
PSV	1422 (65mm)	164361ST161054(9)	4 Mar 2017
PSV	1422 (80mm)	164361ST161054(10)	4 Mar 2017
PSV	1422 (100mm)	164361ST161054(11)	4 Mar 2017
PSV	1422 (150mm)	164361ST161054(12)	4 Mar 2017
PSV	1422 (200mm)	164361ST161054(13)	4 Mar 2017
PSV	1422 (250mm)	164361ST161054(14)	4 Mar 2017
PSV	1422 (300mm)	164361ST161054(15)	4 Mar 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** PSV Global Ltd UK

**Country of Origin:** China

**Brand:** PSV

**Details of Fittings:** Cast iron globe type silent check valve with epoxy coating in blue, red or black under WRAS approval no. 1603543

**Model:** 1422

**Size:** 50mm, 65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

**Body Markings:** PSV 1422 PN16 size in DN

**Expiry Date:** 31 March 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



**1422**