

水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓 Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

wsdinfo@wsd.gov.hk

e-mail

電話 Telephone 2829 4367 圖文傳真 Facsimile

2824 0578

檔 號 Reference

(10) in WSD 3321/16 Pt.1 T/J(1073)

26 August 2016

Approval of "PSV" Gate Valves

Your letter ref. WSD-1100-16-L001 dated 23 May 2016 and subsequent submission received by this department on 17 August 2016 refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1100 (1/2")	160072ST160034B	15 August 2016
PSV	1100 (3/4")	160072ST160034(1)B	15 August 2016
PSV	1100 (1")	160072ST160034(2)B	15 August 2016
PSV	1100 (1½")	160072ST160034(3)B	15 August 2016
PSV	1100 (2")	160072ST160034(4)B	15 August 2016
PSV	1100 (11/4")	160072ST160034(5)B	15 August 2016

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

PSV Global Ltd., UK

Country of Origin:

Taiwan

Brand:

PSV

Details of Fittings:

Stainless steel gate valves

Model:

1100

Size:

1/2", 3/4", 1", 11/4", 11/2", 2"

Body Markings:

PETER size

SMITH 600

CF8M

Expiry Date:

8 May 2021

(for size 11/4")

29 March 2021

(for others)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in fire services plumbing systems may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

(LAM Ching Man) for Water Authority

c.c. WSD 3321/1/82] - without catalogue ME/CS(MC)] - with soft copy only

