



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(536)

4 May 2016

Approval of "AEON" Gate Valves

Your letter dated 16 March 2016 refers.

The licence no. KM 539991 has been examined. It is noted that the British Standards Institution (BSI) has granted Radius Systems Limited the right and licence to use the Kitemark for goods as set out below:

Name of Manufacturer:	Radius Systems Limited
Country of Origin:	China
Brand:	Aeon
Details of Fittings:	Resilient Seated Gate Valve (Blue coloured epoxy powder coating is included and under WRAS approval no. 1307514) 1. Model: Type A Sizes: DN40, 50, 65, 80, 100, 125, 150, 200, 250 & 300 2. Model: Type B Sizes: DN80, 100, 125, 150, 200, 250 & 300

Body Markings:

Body: Cast, logo, pressure, diameter & cast material type.

Label: AEON, website, WRAS, Kitemark, DVGW, EN1074-1-2:2000, DIN 3352, NF E29-324, EPDM, MAX 23°C, weight, turns, part number & barcode.

Expiry Date:

31 July 2018

In view of BSI granting licence to Radius Systems Limited on BS EN 1074:2000 Parts 1 & 2 "Isolating Valves" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fittings if it is found afterwards not suitable for use in fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only



Type A



Type B