



水務署

**Water Supplies Department**

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3321/14 Pt.1 T/J(226)

19 December 2014

### Approval of "PSV" Gate Valves

Your letters ref. WSD-111010112014 and WSD-111026112014 dated 10 November 2014 and 26 November 2014 respectively refer.

Having considered test reports ref. J16962A-2r3 and J16962B-2r3 both issued on 25 November 2014 by the Nutek Systems Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** PSV Global Ltd., U.K.

**Country of Manufacturing:** China

**Brand:** PSV

**Details of Fittings:** Gunmetal (bronze) gate valve

**Model:** 1110

**Sizes:** 65mm and 80mm

**Body Markings:** PN20 (size of valve)  
PSV CC491K

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(LAM Ching Man)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
E/CS(TS)1 ]

