



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號 (2) in WSD 3321/16 Pt.1 T/J(535)

13 April 2016

Approval of “YONGXIANG” Ball Valves

Your letter dated 17 March 2016 refers.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer:	Ningbo Yongxiang Copper Pipeline Co., Ltd.
Country of Origin:	China
Brand:	Yongxiang
Details of Fitting:	Range of spherical valves with lever operating member, bronze bodies, chromium plated brass ball and PTFE seat. Maximum working pressure 25.0 bar, Maximum operating temperature 85°C.
Model:	251A & 252
Size:	251A: 1/2”, 3/4”, 1”, 1 1/4”, 1 1/2” & 2” 252: 1/2”, 3/4”, 1”, 1 1/4”, 1 1/2” & 2”

Marking: Brand logo ('H'), size and PN25 on body.
WRAS 85°C 25BAR, H=HALLMARK PN25 on
operating member.

WRAS Approval Number: 1510952

Installation Requirements: R001

Expiry Date: 31 October 2020

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”


A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(K K LI)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/CS(MC)] - with soft copy only



252



251A