



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1230)

23 September 2016

Approval of "PSV" Strainers

Your letters ref. WSD-901-16-L001 dated 24 August 2016 and WSD-901-16-L002 dated 5 September 2016 refer.

Having considered the test report ref. 163369ST160731A issued on 3 September 2016 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd. U.K.
Country of Origin: Taiwan
Brand: PSV
Details of Fittings: Stainless steel Y-type strainer
Model: 901
Size: DN65, 80, 100, 150, 200
Body Markings: Peter Smith

Expiry Date:

20 June 2021


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in fire services plumbing systems may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



901