

## 水務署

## Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

Telephone

2829 4355

置文傳真 Facsimile

2824 0578

Landing Time of Lateral School

(4) in WSD 3321/17 Pt.1 T/J(527) Reference

22 June 2017

## Approval of "PSV" Check Valves

Your letters ref. WSD-1410B-17-L001 and WSD-1410B-17-L002 dated 12 May 2017 and 1 June 2017 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1410B (½")	170256ST170056(5)	4 May 2017
PSV	1410B (¾")	170256ST170056(6)	4 May 2017
PSV	1410B (1")	170256ST170056(7)	4 May 2017
PSV	1410B (1¼")	170256ST170056(8)A	26 May 2017
PSV	1410B (1½")	170256ST170056(9)	4 May 2017
PSV	1410B (2")	170256ST170056(10)	4 May 2017

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

PSV Global Ltd UK

**Country of Origin:** 

Taiwan

**Brand:** 

**PSV** 

**Details of Fittings:** 

Bronze swing check valve

Model:

1410B

Size:

1/2", 3/4", 1", 11/4", 11/2", 2"

**Body Markings:** 

PSV size in inch PN20

**Expiry Date:** 

6 April 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

(CHAN Chung Kun) for Water Authority

C.C.

WSD 3321/1/82 ] - without catalogue

ME/MC

] - with soft copy only



1410B