



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(912)

13 July 2016

Approval of “CHU LIE” Hydrant Globe Valve

Your letters ref. WSD-604MOKF-L001 dated 3 June 2016 and WSD-604F-L001 dated 17 June 2016 refer.

The licence no. KM 650015 has been examined. It is noted that the British Standards Institution (BSI) has granted Chu Lie Industry Co., Ltd. the right and licence to use the Kitemark for goods as set out below:

Name of Manufacturer:	Chu Lie Industry Co., Ltd.
Country of Origin:	Taiwan
Brand:	Chu Lie
Details of Fittings:	Fire hydrant globe valve, low pressure, oblique type, DN65 flanged inlet
Model:	ABC604F
Body Markings:	“LP”, size, name of manufacturer & “BS5041/1”
Expiry Date:	12 July 2019

In view of BSI granting licence to Chu Lie Industry Co., Ltd. on BS5041-1:1987 "Fire hydrant systems equipment. Specification for landing valves for wet risers" as mentioned above, approval is hereby given to the said water supply fitting to be used on fire service plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fitting if it is found afterwards not suitable for use in fire service plumbing systems in terms of quality or unacceptability of material.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only



ABC 604F