



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號 (5) in WSD 3321/16 Pt.1 T/J(819)

10 June 2016

[Faint, illegible text, likely bleed-through from the reverse side of the page]

Approval of “PSV” Globe Valves

Your letters dated 19 May 2016 and 27 May 2016 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Pipemate International Limited

Country of Origin: China

Brand: PSV

Details of Fitting: Range of globe valves with bronze bodies, incorporating PTFE seats and rising spindle headwork with hand wheel operating members. Maximum working pressure 32.0 bar. Maximum operating temperature 85°C.

Model: 1230

Size: 1/2”, 3/4”, 1”, 1 1/4”, 1 1/2” & 2”

Marking: H(manufacturers logo), size, PN and flow arrow on the body.
H on handwheel

WRAS Approval Number: 1507973

Installation Requirements: R001

Expiry Date: 31 July 2020

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/CS(MC)] - with soft copy only



1230