



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(330)

1 April 2016

Approval of "EUROBRASS 143" Pressure Reducing Valves

Your letter ref. WSD-eurobrass14323022016 dated 23 February 2016 refers.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Rubinetteria Malgorani Pietro SRL

Country of Origin: Italy

Brand: Eurobrass 143

Details of Fittings: `Eurobrass 143` range of adjustable in-line pressure reducing valves with brass bodies incorporating brass diaphragms and NBR seals. Maximum inlet pressure 25.0 bar. Minimum/maximum outlet pressures: 2.5 and 6 bar respectively. Maximum operating temperature 60°C.

Model & Size:

Model	Size (inch)
143.12	½"
143.34	¾"
143.33	1"
143.114	1¼"
143.112	1½"
143.58	2"

Marking:

Manufacturer's logo, size, made in Italy & flow arrow on body.

WRAS Approval Numbers: 1312084

Installation Requirement: R001

Expiry Date: 31 December 2018

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –


“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(K K LI)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
E/CS(TS)1] - with soft copy only



EUROBRASS 143