



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/16 Pt.1 T/J(920)

5 August 2016

[Faint, illegible text, likely bleed-through from the reverse side of the page]

Approval of "PSV" Check Valves

Your letters ref. WSD-1400-16-L001, WSD-1400-16-L002 and WSD-1400-16-L003 dated 7 June 2016, 19 July 2016 and 25 July 2016 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1400 (½")	160067ST160031	6 June 2016
PSV	1400 (1")	160067ST160031(1)	6 June 2016
PSV	1400 (1¼")	160067ST160031(2)	6 June 2016
PSV	1400 (1½")	160067ST160031(3)	6 June 2016
PSV	1400 (2")	160067ST160031(4)	6 June 2016
PSV	1400 (¾")	160067ST160031(5)	6 June 2016

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd., UK

Country of Origin: Taiwan

Brand: PSV

Details of Fittings: Stainless steel spring loaded silent check valve

Model: 1400

Size: ½", ¾", 1", 1¼", 1½", 2"

Body Markings: PETER size
SMITH 1000 WOG
← CF8M

Expiry Date: 29 March 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/CS(MC)] - with soft copy only



1400