

水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電 話 Telephone

2829 4367

置文件真 Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/14 Pt.1 T/J(73)

29 August 2014

Approval of "PSV" Float Control Valves

Your letter ref. WSD-310015042014 dated 15 April 2014 and subsequent submission received on 6 August 2014 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer:

Pipemate International Ltd.

Country of Origin:

Hong Kong

Brand:

PSV

Details of Fittings:

Range of in-line pilot operated float controlled control valves with a blue epoxy coated cast iron body. Maximum working pressure 16.0 bar. Maximum

working temperature 65°C

Size:

DN50 - DN600

Model:

"PSV" Model 3100

Marking:

DN, PN, PSV on body

WRAS Approval Number: 1311331

Installation Requirements: R001

In view of the acceptance by WRAS, I have no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

> "Installation shall comply with the 'Installation Requirements & Notes' of the WRAS's approval letter concerned."

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,

(LAM Ching Man) for Water Authority

WSD 3321/1/82] - without catalogue C.C. E/CS(TS)1

