



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/14 Pt.1 T/J(43)

11 April 2014

Approval of "PETER SMITH" Float Operated Valves

Your letters ref. WSD/AP-18032014-1 and WSD/AP-18032014-1-1 dated 18 March 2014 and 26 March 2014 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: The Peter Smith Valve Company Limited

Country of Origin: UK

Brand: Peter Smith

Details of Fittings: "501 & 501 ZFB" range of equilibrium float valves with cast iron (black nylon coated) or ductile iron bodies and EPDM seals. Maximum working pressure 10.0 bar. Cold Water Use only

Size: DN50, DN80, DN100, DN150, DN200 flanged inlets

Models: 501 & 501 ZFB (zinc free bronze)

Marking:

The Peter Smith Valve Co. Bulwell - Nottingham and pSv logo on data plate. SEP, The Peter Smith Valve Co. Ltd, company contact details, model number, PN and temp rating on data plate. pSv logo, England and size on body.

WRAS Approval Number: 1401037

Installation Requirements: R001, R280

In view of the acceptance by WRAS, I have no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(WONG Kwok Hung)
for Water Authority

Model: 501



501 & 501 ZFB